

API Standard 607 Fourth Edition
With Exxon modifications
Fire Test Report

Performed for

Triangle Fluid Controls Ltd.

www.trianglefluid.com



6 inch Class 300
Durlon® Durtec™ Gaskets

Project Number: 20978
June 2009



Performed by

YARMOUTH RESEARCH AND TECHNOLOGY

434 Walnut Hill Road
North Yarmouth, ME 04097 USA
(207) 829-5359

info@yarmouthresearch.com
www.yarmouthresearch.com

Yarmouth Research and Technology

API 607 4th Edition Fire Test Data

Customer: Triangle Fluid Controls Ltd.	Date: 7/14/2009
Project Number: PN20978	
Specification: API 607 4th Edition	
Product Code: Durlon® Durtec™ Gaskets	
Flange Mfgr: Weldbend	
Nut +Bolt Mfgr: Alloy & Stainless Fasteners/Shih Hsang	
Comments: New bolts, nuts and flanges	
YRT Technician: Matthew J. Wasielewski, P.E.	

Bolt Torques (ft-lbs)

Bolt Location	At Start of Test	At End of Test
Upstream #1	200	100
Upstream #2	200	120
Upstream #3	200	120
Upstream #4	200	100
Downstream #1	200	100
Downstream #2	200	120
Downstream #3	200	120
Downstream #4	200	140

Fire and Cooldown Data:

Start Time:	3:40 PM	(EST)
Average Test Pressure:	30	psig
Combined Leak Rate of Both Gaskets:	1	ml/min
Allowable Leakage:	150	ml/min
Is Leakage Below Allowable?:	YES	

Post Burn Leakage Test

Start Time:	4:20 PM	(EST)
Average Test Pressure:	30	psig
Leak Rate Side A:	0	ml/min
Leak Rate Side B:	0	ml/min
Combined Leak Rate of Both Gaskets:	0	ml/min
Allowable Leakage:	150	ml/min
Is Leakage Below Allowable?:	YES	

Does Gasket Pass API 607 Leakage Requirements?:	YES
---	------------

Witnesses

