Fire Test Report API Standard 6FB, Fourth Edition, 2019

Performed for

Durlon

www.durlon.com

6 inch Class 300 Durlon SWG DRI - ETG

Project Number: 221336 Test Date: November 11, 2021

Performed by

YARMOUTH RESEARCH AND TECHNOLOGY, LLC

434 Walnut Hill Road North Yarmouth, ME 04097 USA (207) 829-5359 <u>info@yarmouthresearch.com</u> <u>www.yarmouthresearch.com</u>

API 6FB FIRE TEST REPORT

Customer: Durlon			Date:	11/11/2021
Project Number: 221336				
Product Description: 6 inch Class 300 Durlon SWG DRI - ETG				
Product Code: 86	70600CBCC			
Specification: API 6FB, Fourth Edition, 2019				
Non-Bending, Type 1 Test				
Gasket Thickness:	0.190	inches		
Seal Area OD:	8.500	Seal Area ID:	7.438	inches
Mean Seal Diameter:	7.969	inches		
Mean Circumference:	25.0	inches		
Allowable Leakage:	25.0	ml/min		
Nominal Test Pressure:	555	psig		
Nut Torque:	270	ft-lb		
YRT Technician: De	an Frank			
Version of YRT's FIRE-Control 6FB Software: B				
Equipment Confirmed to be in Calibration to NIST Standards: Yes				
Burn and Cool Down Test				
		Burn Start Time:	10:15:00	
Burn / Cooldown Duration:			60	minutes
Average Pressure During Burn/Cooldown:			566	psig
Leak Rate During Burn/Cool Down:			1.3	ml/min
Allowable External Leak Rate:			25.0	ml/min
Amount of Times of Array Cal. Disala > 1900 June			10.0	minutaa
Amount of Time of Avg. Cal. Block > 1200 deg.: Were Test Conditions Within Compliance?			19.0 Yes	minutes
were lest	, Conumons	within Compliance?	168	
Was the Leakage Below the Allowable?			Yes]
Depressurization - Repressurization Test				
Average Pressure During Test:			555	psig
Gasket Leak Rate:			0	ml/min
Allowable External Leak Rate:			25.0	ml/min
Was the Leakage Below the Allowable?			Yes	
Does the	Gasket Pas	s or Fail API 6FB?	PASS]
			UNIT OF	11111

Certified By:

Mart Q Hairlash.

Matthew J. Wasielewski, PE

President and Manager

Yarmouth Research and Technology, LLC

