Fire Test Report API Standard 6FB, Fourth Edition, 2019

Performed for

Durlon

www.durlon.com

6 inch Class 300 FG Spiral Wound Gasket Product Code: 8610600BBCC

Project Number: 219501 Test Date: December 6, 2019

Performed by

YARMOUTH RESEARCH AND TECHNOLOGY, LLC

434 Walnut Hill Road North Yarmouth, ME 04097 USA (207) 829-5359

info@yarmouthresearch.com www.yarmouthresearch.com

Yarmouth Research and Technology, LLC

API 6FB FIRE TEST REPORT

Customer:	Durlon		Date:	12/6/2019
Project Number:	219501		2400	12.0.2010
Product Description:	6" 300 FG Spiral Wound G	lasket		
Product Code:	8610600BBCC			
Trouber couc.	COTOCOCEDEC			
Specification:	API 6FB, Fourth Edition,	2019		
Non-Bending, Type 1 Test				
Gasket Thickness:	0.182 inches			
Seal Area OD:	8.25 Seal A	rea ID:	7.13	inches
Mean Seal Diameter:	7.69 inches			
Mean Circumference:	24.2 inches			
Allowable Leakage:	24.2 ml/min			
Nominal Test Pressure:	555 psig			
YRT Technician:	Dean Frank			
Version of YRT's FIRE-Control 6FB Software: B				
Equipment Confirmed to be in Calibration to NIST Standards: Yes				
Burn and Cool Down Test		, m: I	0.40.00	
	Burn Star		8:46:00	• ,
Burn / Cooldown Duration:			minutes ·	
Averag	e Pressure During Burn/Coo	oldown:	576	psig
I	Leak Rate During Burn/Cool	Down:	1.0	ml/min
Allowable External Leak Rate:			24.2	ml/min
		<u> </u>		
Amount of Time of Avg. Cal. Block > 1200 deg.:			16.0	minutes
Were Test Conditions Within Compliance?			Yes	
	r			
Was	the Leakage Below the Allo	owable?	Yes	
Depressurization - Repressurization Test				
Depressurization - Repres	Surization Test Average Pressure Durin	o Test.	567	psig
	Gasket Lea			ml/min
	Allowable External Lea			ml/min
Was	the Leakage Below the Allo		Yes	1111/111111
Was	the Leakage Delow the And	owable:	ies	
Does the Gasket Pass or Fail API 6FB?		PASS		
Certified By: Matthew J. Wasielewski, PE	heicher h.		MATTHE OF WASIELEV	A 1 1 10 100
D : 1 / 1 M			三号: No. 743	37 : 4 =

www.yarmouth research.com

President and Manager

Yarmouth Research and Technology, LLC